Scott. H-27—60,004—17-11-48

Education (P.H) (1949) Department.

MS SERIES.

G.O. NO. 3590 P.H

Dated 12 - 10 - 49

[Despatch Abstract.]

Building- Private Medical institutions —
St Joseph's Leprosy Hospital and Asylum
Kankanady- Revised plans and estimate
Approved.

Medical Department

From

Col. S.L. Bhatia, CIE.MC.MA.MD(CANTAB)FRCP(LOND)(VE) FRS
Surgeon-General with the Government of Madras.

The Secretary to the Government of Madras,
Education and Public Health Department.

Ref.No.-34116-12-B/48 Dated 26-10-1948.

Sir,

Sub: Grant - Buildings - Private Medical Institutions - St. Joseph's Leprosy Hospital and Asylum, Kankanady - Half grant for the construction of additional buildings - Plans and estimates.

Ref: G.O.No.Ms. 1287 P.H. dated 20-4-1948.

With reference to paragraph 4 of the G.O. cited above, I forward herewith the plans and estimates for the construction of additional buildings at the St. Joseph's Leprosy Asylum and Hospital, Kankanady, Mangalore duly revised by the Consulting Architect to Government in the light of the instructions issued by the Chief Engineer, Public Works Department in his letter No. 3520 P.W.W./47-1 dated 27-10-1947 for the approval of Government. A copy of letter No. 592-M/48 dated 25th October 1948 of the Consulting Architect to Government containing his general remarks on the plans and estimates is enclosed for the information of Government. The management may be instructed to follow the corrections pointed out by the Consulting Architect to Government during execution.

2. The Director of the Leprosy Asylum and Hospital requests permission to start the work immediately. It is therefore requested that early orders of Government may kindly be issued in the matter.

Yours faithfully

26.10

For Surgeon-General with the Government
Madras.

26/10/48

Copy of letter No. 592 M/48 dated 25th October 1948 from the Consulting Architect to Government, Chepauk, Madras to the Surgeon-General with the Government of Madras.

Sub: St. Josephis Leprosy Hospital & Asylum at Kanakanady (South Kanara District).
Ref: Your letter No. 34116-1-Bud/48 dated 3-5-1948.

I returned herewith the plan and estimates for the above work, embodying the suggestion of the Chief Engineer. The sufficiency or otherwise of the rates for the various items of work could not be verified in the absence of the detailed data. It is presumed that the rates provided will be sufficient. The correction made in pencil in the estimates may be followed during execution.

The following general remarks are offered which can however be attended to during execution.

1) The Operation Theatre, as now shown in the drawing faces south and west. For uniformity of light, ~~kkk~~ it is better the theatre windows face north. It appears that the drawing for the operation theatre has been prepared for the original siting. It is possible to locate the building in its new place so that the gable-end of the theatre faces north to provide ample north light to the theatre.

2) No detailed drawing and estimate has been furnished for the kitchen block. For purposes of grant, the amount provided may be left as it is, as this is considered to be reasonable one.

3) The actual length of compound wall to be built round the woman's ward is not known as nothing has been shown as such in the drawing. The provision for this item may however be left as it is.

The total cost of the scheme now comes to Rs. 99,000/- against the provision of Rs. 1,06,500/- and this figure may be taken for purposes of grants.

The enclosures sent with your letter cited above are returned herewith.

/true copy/

For Surgeon-General with the Government of Madras.

S.r.26/10

Ers II-L2

Please see 2 s/ller.

Encl. - 79217 L2/ms - 1 Mt D/s 11.11.98

Subj. - Grant. Buildings - Private Medl. Instn. - St Joseph's Leprosy Hospl. & Asylum at Kanikanady - Help grant for the constn. of additional buildings - Revised plans testimonials

Ref. - From the SE no. 3411/6.12B/ms D/26.10.98

Referred to the CE (NWD) Guwahati for remarks.

Sd/- [illegible]

To

The CE (NWD) Guwahati,

(with the plans & other - marks at (4) both sets with reply)

SE (NWD) for remarks.

Sd/- [illegible] 9/11

Sd/- [illegible] 4.11.98

EXR. 6.12.98. Mt 21/12/98

IMMEDIATE.

From

Sri Rao Bahadur
A.R.Venkatachari, B.E., M.I.E.(Ind).,
M.Am.Soc.C.E., I.S.E.,
Chief Engineer (Irrigation) General Branch,
Chepauk, M a d r a s.

To

The Secretary to Government,
Education and Public Health Department,
Fort St. George, M a d r a s.

Letter No.6756-PWW/48-1 d/15-11-1948.

Sir.

GRANT--BUILDINGS--PRIVATE MEDICAL INSTITUTION--ST. JOSEPH'S LEPROSY HOSPITAL AND ASYLUM AT KANKANADY--HALF GRANT FOR THE CONSTRUCTION OF ADDITIONAL BUILDINGS--REVISED PLANS AND ESTIMATE.

Ref:- Government Memorandum No.79217-G2/48-1.P.H. d/5-11-48.

A copy of Surgeon-General's letter No.34116-12-B/48 d/26-10-48 referred to in the above Government Memorandum has not been received in this Office with the above reference. A copy thereof may please be furnished.

for Chief Engineer, P.W.D.(General)

ssc/15-11.

Encl 2.

Encl 79217 G2/MR-2 TH dated 18-11-48

Subj:- Grant - Buildings - Private Medl. Institutions - St Joseph's Leprosy Hospital Kankanady - Half grant for the const of buildings - Revised plans & estimate

Ref:- from the CE (Irrign.) letter dt no 6756-TW1 /48-1 dt/15.11.48

A copy of the S G's letter no. 34116-128/MS dt/26.10.48 is furnished.

for Secretary to Government

To
The CE (Irrign.)
General Branch
Chepauk, Madras
(with a copy of the 2 cys)

2
17.11.48
JRR
17.11.48

Gone
JRR
18-11-48

18/11

24/11

L. C. Pais, B.A., B.L., M.L.A.,
ADVOCATE,
PARLIAMENTARY SECRETARY
LOCAL ADMINISTRATION,
CHAIRMAN MANGALORE MUNICIPALITY.

LIGHTHOUSE HILL ROAD,
MANGALORE

Date 10-12-1948

Mr. Coorey, I.C.S.,
Government Secretariat,
Fort St. George, Madras.

Dear Mr. Coorey,

Re: Grant to St. Joseph's Leprosy Hospital, Kankanady, Mangalore.

You may remember, Fr.Pinto, Director of the Institution and myself saw you personally in the above matter about 6 weeks ago. Fr. Pinto on that occasion also saw the Superintendant of your Department. As he was talking to him, the plans and estimates for the above work were received by him.

On going through them, he assured Fr.Pinto that within 5 or 6 days, they would be sent to the Surgeon General with the final approval. He also told Fr.Pinto that a copy of the communication would be sent to him direct.

Fr.Pinto has been anxiously waiting for the papers. A reminder was also sent by him to the Surgeon General, about two weeks ago. The Surgeon

P.T.O.

27 DEC 1943

General says in turn that he has sent a reminder to the Government, a copy of which has been forwarded to Fr.Pinto.

May I request you to see tat the matter is expedited as water is getting scarce to start work and the grant has to be availed of by the end of March.

Yours sincerely,

97205

Ms. EPH

68 23/11/43

23/11

Encl 79217 L2/Pt.4 Pt 20/30.12.43 & 3 abstr

Encl 79217 L2 communication to the CE (PWD) General in continuation of this dept Encl. 79217 L2/Pt. 4 Pt 20/5.11.43. He is requested to expedite his reply to the Encl referred to.

23/12 23/12 JRH 23.12.43

3 Jan 44 To the CE(G

PUBLIC WORKS DEPARTMENT



From
Sri Rao Bahadu.
A.R.Venkatachari, B.E.,M.I.E.,(Ind.)
M.Am.Soc.C.E., I.S.E.,
Chief Engineer (General), P.W.D.
Chepauk, M a d r a s.

To
The Deputy Secretary to Govt.,
Edn. Public Health Department.

Letter No. 6755.PWN/48-2 Dated 28-12-1948.

Sir,

Sub: Grant - Buildings - Private Medical Institutions - St.Joseph's Leprosy Hospital,Kankanady - Half grant for the construction of buildings - Revised plans and estimates.

Ref: Govt. Endt. Nos.79217.G.2/48-1 P.H. dated 5-11-48 and 79217.G.2 P.H. dated 18-11-1948.

The plans and estimates for the work mentioned above are forwarded herewith with the following remarks:-

2. Site plan.--

(i) In view of the reasons given by the Director of the Hospit Engineer-in-charge of the work and the District Medical Officer, South Kanara District, the new sites now proposed in S.No.14 for the New Women Block and Operation Block may be approved.

(ii) The position of the kitchen and the compound wall propos have not been shown in the site plan.

3.i. Operation block. Revised detailed plan to suit the new site since proposed embodying therein the instructions contained in Consulting Architect's No.592/M/48 dated 25-10-48 in regard to orientation has not been furnished nor has the estimate been ~~xxxxxxx~~ revised.

3.ii. Kitchen and compound wall.-- Detailed plans and estimates have not been prepared.

3.iii. Details of soil and sub-soil particulars of the site chosen for the construction of the new buildings, detailed plans and estimate for the construction of septic tanks and detailed data for the rates adopted in the estimate have not been furnished.

4. The Director of the Hospital may be asked to furnish the above particulars to enable proper scrutiny of the plans and estimates. As now sent they are not in a state fit to be recommended to Government for approval.

Venkata Rowanan
29-11-48

for Chief Engineer, P.W.D.(General).

Enc: 1 File of plans and estimates in 26 sheets.

29/12

TPC.28/12/48

Memo 79217 Ga/HS. Sl 14 D/8-7-49

Sub:- Grant. Bailongo - Private med. institutions. St Joseph's Leprosy Hospital & Asylum at Kankanady - Revised plans & estimates - Approval of.

Ref: From the SA no. 34116-128/HS D/26 Oct HS
CE. Letter no. 6755 PW W/HS-2 D/28-12 HS

A copy of the remarks of the CE (General PWD), in his letter read above is communicated to the SA. In the circumstances stated by the Chief Engineer, the SA is requested to obtain

from the Director of the Leprosy Asylum & Hospital at Kankanady and furnish the required particulars, so as to enable the Govt to approve the revised plans & estimates. The plans & estimates furnished by the SE are returned herewith

7.1.69

7.1.69

7.1.69

Forwarded
19/1

To

The SE (with a copy of Mr 11-12 & and the plans & estimates at (H).)

Copy to the CE (Genl) PWD, Madras.

G2

TELEGRAMS:
"Specific"
Mangalore.

FATHER MULLER'S CHARITABLE INSTITUTIONS

HOMŒOPATHIC POOR DISPENSARY
LABORATORY AND DEPOT.

Mangalore, P. O. Kankanady,
SOUTH INDIA.

RY. STATION:
Mangalore.

No. D/9506

24 FEB 1949

22nd February 1949.

Dear Mr. Prabhu:

14280

I have been long waiting for final orders from Government to start the work of a leprosy hospital block for the female leprosy patients of our St. Joseph(s Leprosy Hospital and Asylum here at Kankanady.

(A)

Government sanctioned a building grant of --- Rs.49,750/- on 20-4-1948 - G.O. (Ms.) No.1287, Public Health. The plans and estimates that were still with the Chief Engineer were finally submitted to Government on the 29th of October 1948 with recommendations from the Surgeon-General. As I was assured by the office of the secretariat that orders would be issued within a week from that date, I returned from Madras as my stay there was said not to be necessary.

Materials are kept ready so as to start work as soon as the order will be received; as the work has to be started and a part of the grant has to be drawn during the current official year which ends on 31-3-1949, I am anxious to start the work --- immediately.

I shall be much obliged if you could kindly help me in this matter by obtaining final orders. I have also approached the Minister for Public Health in this connection and requested him to do the needful at an early date.

Yours sincerely,
Reg. Trustee
DIRECTOR

To
Joseph M. Lobo Prabhu Esq., I.C.S.
Joint Secretary to Govt.
Education & Health Dept.
Govt. Of Madras,
Madras.

Id. M also spoke - Put up file today

24/2/49

SECRETARIAT TO GOVERNMENT
24 FEB 1949

Edn. and P.H. Department
G2.

Sub:- Grant - Buildings - Private Medical institutions - St. Joseph's Leprosy Hospital and Asylum at Kankanady - Revised plans and estimates - Approval of

---

Read:- Letter from the Director, Father Muller's Charitable Institutions, No. D/9506 dated 22-2-49.

Memo No. 79217 G2/48-6 P.H. dated 26.2.49

The attention of the S.G. is invited to the Govt. memorandum No. 79217G2/48-5 P.H. dated 8-1-49. He is requested to report ~~immediately~~ at once whether the particulars required by the Chief Engineer in the matter have been called for from the Director of the Leprosy Asylum and if not to obtain the particulars immediately and submit his report.

Note:- No time limit has been prescribed in G.O. No. 1287 P.H. dated 20-4-48 for the drawal of the grant. This will be done when ~~approving~~ the revised

To

The S.G.

The Director, Homoepathic Poor Dispensary, Kankanady (with a copy of pp 11-14 c.f)

plans and estimates are approved.

JRR
24/2/49

SPECIAL. J.S.(P.H.)

When I was at Mangalore recently, the Rev. Father in charge of Fr. Muller's Hospital, Kankanady told me that he had collected all the material necessary to start the work of the buildings for the extension of the leprosy clinic there but that for want of Govt. orders he had not started the work. Expeditious orders sanctioning the commencement of the work may be issued. If, for any reason, this cannot be done, the position may be explained to the party by a letter.



Not found 42 41

16570

TELEGRAMS:
"Specific"
Mangalore.

FATHER MULLER'S CHARITABLE INSTITUTIONS

HOMŒOPATHIC POOR DISPENSARY
LABORATORY AND DEPOT.
Mangalore, P. O. Kankanady,
SOUTH INDIA.

RY. STATION:
Mangalore.



No D/9574

2nd March 19 49.

Dear Mr. Lobo Prabhu:

Subject: Grant - Buildings - Private Medical Institutions St. Joseph's Leprosy Hospital & Asylum at Kankanady - revised plans and estimates - approval of.

I have this day received from your office, copy of your letter to the Surgeon-General dated 26-2-1949 on the above mentioned subject. I have also received copy of letter 6755 - P.W.D.48-2 dated 28-12-1948 from the Chief Engineer to the Deputy Secretary to Government Education and Public Health Department and I thank you for the same.

Yesterday I received from the Surgeon-General, the plans and estimates in ~~re~~ original, with instructions to have them revised and completed and submitted at an early date. The work of the revision etc. has now been taken up and will be submitted to the Surgeon-Genral as soon as the same is ready.

Yours sincerely,

Reg. Pinto

DIRECTOR

To
Joseph M. Lobo Prabhu Esq., I.C.S.,
Joint Secretary to Govt.
Education & Public Health Dept.
Govt, of Madras,
Madras.

GP

Medical Department.

From

The Surgeon-General with the Govt.of Madras,Madras.

To

The Joint Secretary to Government,
Education and Public Health Department,Madras.

Ref:No.341E6-16.B/48 dated 3 -3-49.

Sir,

Sub:- Grant-Buildings - Private Medical Institutions - St. Josephs Leprosy Hospital and Asylum at Kankanady - Revised plans and estimates - Approved of.

17307

Ref:- Government Memo.No.79217-G2/48-6 P.H. dated 26-2-1949.

The plans and estimates received with Government Memo. No.79217/48-5 P.H. dated 8-1-49 have been forwarded to the Director, St. Joseph's Leprosy Hospital and Asylum, Kankanady for

-2-

for revision in the light of the instructions contained in the letter of the Chief Engineer, Public Works Department, Madras and retransmission to this office at a very early date together with the other particulars required by the Chief Engineer.

The plans and estimates will be submitted to the Government immediately on receipt.

Yours faithfully,

for Surgeon-General with the Government of Madras.

a.m.3.3.

J.S(PH)

Telegrams:
"Specific," Mangalore.

By. Station:
Mangalore.

Father Muller's Charitable Institutions
Kankanady, Mangalore.
(South India)

No. [illegible] 1949

6 MAR 1949 1 - 3 - 1949

Dear Sir

17316 — I have just received from the Surgeon Generals office the plans and estimates of buildings for extension of the Leprosy Hospital and asylum at Kankanady for resubmission after revising them as per directions of the Chief Engineer.

I have also received from the joint Secretary to Govt Mr. Lobo Prabhu copy of his letter to the S.G. directing him to attend to this matter early.

I thank You for having arranged all these preceedings I hope to resubmit the plans to G. early with humble respects

I remain
Yours obedtly
Rev. Auto
Director

Medical Department.

From

Dr. A.S. Mannadi Nayar, M.B.B.S., Ph. D. (Edin.)
Surgeon-General with the Govt. of Madras, Madras-6.

To

The Secretary to Government,
Education & Public Health Department, Madras.

Ref: No.34116-21-B/48. Dated 17-5-49.

Sir,

Sub: Grant - Building - Private Medical Institutions - St. Joseph's Leprosy Hospital and Asylum at Kankanady - Plans and estimates - Revision of.

Ref: Govt. Memo.No.79217-G2/48-5- P.H. dated 8-1-49 and this office letter Ref.No.34116-20-B/48 dated 12-5-49.

...

I forward herewith the plans and estimates since received from the Director, St. Joseph's Leprosy Hospital and Asylum, Kankanady, Mangalore duly revised in the light of the instructions contained in letter No.6755-P.W.W/48-2 dated 28-12-48 of the Chief Engineer (General) Public Works Department, Madras communicated with the Government Memo. cited above. I also forward herewith a copy* of letter dated 14-5-49 from the Director of the Leprosy Hospital for the information of the Government.

According to the revised plans and estimates, the total cost of the work amounts to Rs.1,10,000/- and the half-grant payable by Government would therefore be Rs.55,000/-

Yours faithfully,

for Surgeon-General with the Govt. of Madras.

kvr 17-5.

*Copy of letter.

Ref: Surgeon-General's No.34116-15-B/48 dated 21-2-49
Chief Engineer's No.6755-P.W.W/48-2 dated 28-12-48.
3520 P.W.W./47-1 of 27-10-47 to Government.

...

With reference to the above, I resubmit herewith the plans and estimate for the above work duly revised as per

instructions...

instructions of the Chief Engineer.

2. (i) The site plans - remarks noted.
(ii) the position of the kitchen and the compound wall has since been marked on the site survey plan

3. (i) Operation block:- a new plan with a detailed estimate to suit the new site as per instructions of the consulting architect contained in his No.592-M/48 dated 25-10-48 has since been prepared and enclosed. The height of the wall is kept up to 13' - 0" and the mosaic tiled flooring is provided for instead of marble slab flooring.

(ii) Kitchen and compound wall - detailed plan and estimates since prepared and enclosed herewith.

(iii) Detailed plans and estimates for septic tanks, with dispersion trenches, are now enclosed. Soil and subsoil particulars have also been furnished on the plan.

The whole estimate has now been recasted based on the P.W.D. schedule rates and the data for all items of work, now furnished along with the revised estimate. The whole estimate amounts as per detailed estimate, now prepared comes to Rs.1,10,000/- against the approximate amount of Rs.99,500/- furnished in the 1st instance on 27-9-47 which was taken for grant purposes. The cost of chapal Rs.7000/- is not included in this estimate.

request early action in the matter.

/True copy/

for Surgeon-General with the
Govt. of Madras.

Dpo(i) 24/5 Encl 79217 G1/48-8 HH Dated. 24.5.49.

Sub:- Grant - Buildings - Private - medl institution - St Joseph's Leprosy Hospital & Asylum at Kankanady - Half grant for the construction of addl buildings - revised plans & estimates.

Ref:- From the SG no. 34116-21 B/48 20/17.5.49

—.

The attention of the CE. PWD General is invited to his letter no. bTSS. PNW/48.2 dated. 28.12.48. He is requested to sanction the revised plans & estimates enclosed

herewith and to return them
at an early date together with
his remarks if any.

2
23/5/04.

23/5/04

21/5/04.

To

The C.E. (NWD)
General. (with
enclosures at ⓐ and
a copy of H 33-34 q)
. Ex Ron Eq. 6. no
200 ,,

PUBLIC WORKS DEPARTMENT.

From
Sri K.S.Tirumale Ayyangar, B.E.,
A.I.E., I.S.E.,
Chief Engineer, P.W.D.(Buildings),
Chepauk, M a d r a s.

To
The Secretary to Government,
Education & Public Health Dept.,
Fort St. George, M a d r a s.

Letter No.6755-PW/48-4, dated 20-6-1949.

SECRETARIAT
24 JUN 1949
Received

Sir,

Sub: Grant--Buildings--Private Medical Institution--St. Joseph's Leprosy Hospital and Asylum at Kankanady--Half grant for the construction of additional buildings--Revised plans and estimate.

Ref: Your Endorsement No.79217/G1./49-8-P.H. d/24-5-1949.

The revised plans and estimates received with your endorsement No. quoted above have been scrutinised and the following remarks are offered.

48207

2. NEW BLOCK FOR WOMEN PATIENTS.- In paragraph (4) of this Office letter No.3520-PW/47-1, dated 27-10-47, it was pointed out that through vertical joints are to be provided between the central and side blocks. The positions of vertical joints were also marked on the plan. An additional truss will be necessary by the side of the vertical joint. But no provision has been made in the estimate for the same.

2.1. Structural calculations for pressure on soil, intensity of pressure on concrete and masonry, thicknesses of R.C.C. lintels sizes of roof timbers and sizes of members of trusses are required to check the adequacy of the provisions made in the estimate.

2.2. Width of foundation concrete as shown in the plan is 3'-6" while the estimate provides for 3'-0" only. Widths of masonry footings in foundation and basement as per plan are 2'-6" and 2'-0" while the estimate provides for 2'-0" and 1'-6". These discrepancies have to be reconciled.

2.3. The alteration to the positions of sanitary blocks was originally suggested in this Office letter No.3520-PW/47-1, dated 27-10-1947 when the building was proposed in S.No.13 with two side wings projecting towards the south. Since the building is now proposed in S.No.14 with the two side wings projecting east there is no need to change the positions of the sanitary blocks and these may be located at the original positions vide fly slip attached to the plan. The detailed estimate does not require alterations as no corrections were made for the altered positions of sanitary blocks suggested previously.

2.4. No provision has been made in the estimate for the partition walls for cubicles in the Sanitary Block. These should be provided for.

2.5. Damp-proof course should be provided for all walls as per M.J.S.S.No.38.

3. OPERATION THEATRE.- The revised plan and the estimate for Rs.13,500/- for this sub-work may be approved subject to the following remarks being attended to during execution.

3.1. Damp-proof course may be provided for all walls as per M.J.S.S.No.38. Sun-shades may be provided for the windows. The exact kind of country wood proposed to be used on the work is not furnished. The Engineer in charge may be asked to satisfy himself about the adequacy of the sizes of roof timbers proposed. Same rate of Rs.500/- for each iron framed glazed sash window is provided both for sizes 6'x10' and 5' x 10'. The rate is rather excessive but may be allowed for purposes of the estimate.

4. KITCHEN.- Structural calculations have not been furnished for sections of foundations, roof timbers and R.C. lintels. The addition of a second store room and a staircase will result in some economy in cost of the work as compared

by the omi sion of these two rooms. A ladder could be provided in the kitchen for admittance into the loft. These suggestions are marked in red on plan. A damp-proof course may be provided for all walls as per P.W.D.S.No.38.

5. SEPTIC TANK AND DISPERSION TRENCH.- The location of the septic tank and dispersion trench have not been shown in the site plan. Special care should be taken in siting such installations as they would prove a source of contamination to ground water. The site should be located after considering such factor as the lie of the country, level of drinking water and nature of soil, etc. However atleast a distance of 100 ft. away from drin in water source should be allowed in locating the tank and trench.

5.1. The more recent Design P.H.B.D.No.05/1943 and P.H.B.D. No.D of 1943 may be adopted for the septic tank and dispersion trench respectively. The length of dispersion trench may not be not less than 45 ft.

6. COMPOUND WALL.- Laterite masonry to a depth of 2' is proposed in foundation. It is desirable to have a levelling course of concrete 6" deep in foundation and the depth of masonry reduced to 1'-6", Nessary weep-holes may be left as suitable intervals in the compound wall at ground level so that rain water my pass through. Subject to the above remarks being attended to during execution, the estimate may be approved for Rs.10,000/- for this sub-work.

7. The plans and estimate may be returned to the Director for revision of the plans and estimate in the light of the remarks mentioned above in respect of New Block for Women Patients, Septic tank and Dispersion trench and Kitchen block.

New Kate Rowanan
22-6-43

for Chief Engineer, PWD.(Buildings).

d
20/6.

Enc.-
One file of plans and estimates.

ssc/20-6.

3
EPHG

Memo 7921) G1/4f - 9 PH D/29.6.49.

Sub:- Grant. Buildings - Private Med. Institutions - St Joseph's Leprosy Hospital & Asylum at Kankanady - Revised plans & estimates - approval of

Ref:- From the SG no. 34116.21 B/48 D/ 17.5.49
From the CE, PWD (Buildgs)
Letter no. 6755-PWH/48-4 D/20.6.49

A copy of the remarks of the CE, PWD (Buildings) in his letter read above, is communicated to the SG. In the circumstances stated by the C.E, the SG is requested to get the plans & estimates recast

by the Director of the Hospital, on the lines indicated in the CE's letter. The plans & estimates enclosed by the SA with this letter read above are returned herewith.

2

25 Govt.
JRR
28.6.49.

28/6/49

28/6/49.

To

The SG (with a copy of 31-32 M&T-38-Q & the plans & estimates as in orgl.)

Ref. No.34116-27-B/48 -Office of the Surgeon-General with the Government of Madras, Madras 6, Dated 17-8-49.

From

Dr.A.S.Mannadi Nayar, MBBS., PH.D(Edin).,
Surgeon-General with the Government of Madras.

To

The Secretary to Government,
Education and Public Health Department, Madras.

Sir,

Sub: Grant- Buildings- Private Medical Institutions-St.Joseph's Leprosy Hospital and Asylum at Kankanady-Revised plans and estimates-Approval of.

Ref: Govt.Memo No.79217-G1/48-9 PH dated 29th June 1949- and this office letter Ref.No.34116-25 /B/48 dated 19-7-49.

The plans and estimates since received from the Director, St.Joseph's Leprosy Hospital and Asylum, Kankanady, Mangalore duly revised in the light of the instructions contained in letter No.6755 -PWM-4 dated 20-6-49 of the Chief Engineer Public Works Department Madras communicated with Government Memo cited above are forwarded herewith. A*copy of letter dated 11-8-49 from the Director, St.Joseph's Leprosy Hospital and Asylum, Kankanady is also enclosed for the information of Government.

It is requested that approval of Government to the plans and estimates may kindly be obtained at a very early date.

Yours faithfully,

for Surgeon-General with the Government of Madras.

RS.17.8

*Copy of letter.

Ref: No.34116-23-B/48- dated 11-7-49 and Chief Engineer's No.6755-PWM/48-48-4 dated 20-6-49.

With reference to the above I resubmit under separate Registered book post plans and estimate duly revised as per instructions of the Chief Engneer.

Para 2. New block for women patients :-

Since the construction site was changed to S.No.14 where the soil and sub-soil met with ~~xxxxxxx~~ is of laterite strata with little gravel, the provision for vertical joint was not made in the estimate. Since it is again pointed out in C.E's No. quoted above, necessary provisionfor extra truss has now been made in this estimate.

Para 2. (1).

Structural calculations for pressure of soil, sizes of timbers etc, are furnished now. Regarding the trusses, it is proposed to have the the trusses, of 18-'-0" span at 10'-0" apart and the sizes of members as detailed in the M.D.S.S will be adopted and hence no separate calculations are furnished.

2.(2). Width of foundationconcrete will be only 3'-0" and 1'-0" thick and the masonry footings and basement will be 2'-0" and 1-' 6" respectively depending on the size of the stones 18"x9"x6" available. The masonry foundation height has been altered from 2'-0" to 2'-6" since the depth of concrete is kept up to 1-'-0" which is found to be sufficient, as the soil and sub-soilbeing laterite strata mixed with little gravel.. Necessary corrections since made in the plan and estimate.

2.(3). Instructions noted and the work will be done as per instructions.

2.(4) since included in the estimate for the main block.

2.(5). Damp-proof course has since been provided in the

estimated for all main walls excepting the verandah retaining walls as per M.D.O.S.No.38.

Para 3 and
3. (1). Operation Theatre:

All wood work will be of best Nirolbhogi wood. The shutters will be of jack wood. Teakwood will be used for shutters if available. All the other remarks noted and will be attended to during execution.

4.Kitchen:- Structural calculations for all items have now been furnished . The provision for a second store room and the staircase room have been omitted., considering the economy in cost of the work and a ladder has been provided in thekitchen room itself, for admittance into the loft.

Damp proof course with cement mortar 3/4" thick as being done usually also has been included in the estimate.

5. Septic tank:-

The location of the septic tank and dispersion trench have now been shown on the plan. All the remarks since noted.

5.(1). The recent designs mentioned are not readily available in any of the offices here. Necessary corrections in the estimate or fresh estimate will be prepared soon after receipt of the revised recent designs from the Sanitary Engineer to the Government of Madras.

6.Compound wall:- Remarks noted and will be attended to during execution

7.The plans and estimate have since been revised in the light of the remarks of the Chief Engineer, and resubmitted herewith for early sanction.

In this connection I have to mention that this is the best time for excavating foundation. , soil being little soft due to rains as well as to start the masonry work, as much water will not be necessary. Further there will be dearth of supply of water during summer after February and the available water we get from all the wells together at times will be just sufficient for the use in the hospital

I therefore request that permissionmay please be granted to start the work as per this estimate duly revised in the light of the remarks of the Chief Engineer vide his No.6755- PWW/48-4 dated 20-6-49 so as to facilitate me, to complete the work early before the time when water supply is restricted.

/True copy/

9.8.49.

for Surgeon-General with the Government of Madras.

Memo 79217 G1/48. 1267 D/ 24.8.49.

8/25/8.

Sub:- Grant. Buildings - St Joseph's Leprosy Hospital & Asylum at Kankanady - Revised plans & estimates - Approval of.

Ref:- From the SG no. 34116.27 B/WS D/ 19.8.49

The plans & estimates, revised duly by the Director, St Joseph's Leprosy Hospital & Asylum at Kankanady on the lines indicated by the CE in his letter no. 6755 - PWW-4 D/ 20.6.49 are forwarded herewith. The CE PWD (Buildgs) is requested to

31-32
~~39-32~~ cf

Scrutinise the revised plans & estimates & to return them at a very early date, together with his remarks, if any. A copy of the letter from the Director of the Hospital received along with the revised plans & estimates is also enclosed.

Executive

23/8/89

To

The CE, PWD,
(Bangalore)
(with a copy of the Director's letter on pages 36-37 & the plans etc at ⓦ wrongly)

36-37

Plans sent
[illegible]

OFFICE OF THE

Date 194

Hours Minutes

TELEPHONIC MESSAGE.

From	To
The Dy. Chief Engr. Bldgs. P.W.D.	The Addl. Secy. to Govt.

Sub:- Grant — Bldg. St. Joseph Leprosy Hospital + Asylum at kunkanady - revised ~~grant~~ plans and estimates approval of

Ref. Govt. Memo No. 79217 G1/48-H P.H. dt. 24 & 49.

The revised plans + estimate stated to have been sent along with the above Govt. memo have not been received in this office. Please send the same very urgently for enable me to sanction them

(Please write on both sides.

49

Office of the Chief Engineer,
General, Chepauk, Madras.

Post copy of Telephonic Message No.0755 P.W./48-6 dated 2nd September 1949. 67825

From

The Deputy Chief Engineer, P.W.D.(Buildings),
Chepauk, Madras.

The Addl. Secretary to Government,
Education and Public Health Department.

Sub: Grant - Buildings - St.Joseph's Leprosy Hospital and Asylum at Kankanady - Revised plans and Estimates - approval of - Revised plans and Estimate.

Government Memo No.79217 G1/48-12 P.H. dated 24-8-1949.

The revised plans and estimates stated to have been sent along with the above Government memo have not been received in this office. Please send the same very urgently to enable me to ~~scrutinize~~ scrutinize them.

/True copy/

VB/2-9.

Superintendent. 2/9

P.C. to go.

E in L No 1 Hg 1

Telephonic Message.

Please 2 6 Wg

To The Dy Chief Engineer, PWD (Bridges).
Chepauk, Madras.

Discussed 20/8/69

Sub:- Grant. Bridges - St Joseph's Leprosy Hospital & Asylum at Kanicanasy - Revised plans & estimates - Approval of

Ref - Reference Tgram. No. 6755 PWN/Work 2/ 2.9.69

The plans & estimates which were ~~not~~ omitted to be enclosed with Govt Memo no. 79217 Gi1/69-12 dt 2/24.8.69 were sent subsequently on 30/8/69.

P C to go

2 Sept 69

5/9/69

PUBLIC WORKS DEPARTMENT.
Letter No.6755 PWW/48-7 Dated 24th September 1949.

From
Sri M.S.Thirumale Ayyangar, B.E.,
M.I.E., I.S.E.,
Chief Engineer, P.W.D. Buildings,
Chepauk, M a d r a s.

To
The Secretary to Government,
Education and Public healt
Department,
M a d r a s.

97 SEP 1949

Sir,

Sub: Grant - Buildings - St.Joseph's Leprosy Hospital and Asylum at Kankanady - Revised plans and estimate -
Ref: Your Memo.No.79217 G1/48-12 P.H. dated 24-8-1949.

The estimate for the work mentioned above may be approved for Rs.1,10,000/- subject to the remarks mentioned below.

2. New Block for Women Patients. Provision of through vertical joints is not necessary as the soil and sub-soil is how reported to be of laterite strata and is uniform throughout. Provision now made by the Director for two additional trusses may be deleted as additional trusses will be required only if through vertical joints are provided.

3. It is stated that the sizes of members of trusses as mentioned in the M.D.S.S. will be adopted. The Director may be informed that the sizes specified in the M.D.S.S.are for use of teak wood. Since bogai wood is proposed to be used on the work, the sizes of members should be designed to suit.

4. Kitchen. A central wooden beam to support the loft in the washing room is proposed. Since there is an arch opening on one wall and a window on the other wall just below the proposed beam it is not desirable to provide the beam (which would transmit a concentrated load) at that place. As the width of the room is only 12'-0" joists in that direction may be provided so as to distribute the load on the side walls.

5. Septic Tank and Dispersion Trench. The Director has stated that the latest designs will be obtained from the Sanitary Engineer and the estimate suitably revised. This may be accepted.

6. The plans and estimate forwarded with your Memo.No. quoted above are herewith returned.

Kalpakkam Lecture.

R. Lakshmanan 24/9/cp
for Chief Engineer, P.W.D. Buildings.

Enclo: 1 Fresh estimate.
6 plans
1 old estimate.

24/9

NS/24-9.

ST. JOSEPH'S LEPROSY HOSPITAL & ASYLUM

KANKANADY,

Mangalore, 26th September 1949.



Rev. Reginald Pinto
Director
St. Joseph's Leprosy
Hospital & Asylum,
Kankanady, Mangalore.

To

J.M.Lobo Prabhu Esq., I.C.S.,
Joint secretary to the
Government of Madras,
Madras.

75339

Sir: 49-57 below ~~1-5-49~~ -/53 below

In enclosing herein copy of my letter to the Surgeon-General with the Govt. Of Madras dated 11-8-1949 and another No.D/3219 dated 26-9-1949 I request that you will be pleased to expediate grant of licence for the building or at least permission to start the work of the leprosy block and the leprosy operation theatre as the monsoons are almost over and if the construction is delayed any longer there will be real difficulty to carry on the work for want of water.

Yours sincerely,

Reg. Pinto

DIRECTOR

This is getting pretty old. And Secretary may like to keep up the progress

28/5

Add see 85/219

ST. JOSEPH'S LEPROSY HOSPITAL & ASYLUM,
KANKANADY,

D/3219

Mangalore 26th September 1949.

From

Rev. Reginald Pinto
Director
St. Joseph's Leprosy Hospital & Asylum,
Kankanady, p.o, Mangalore.

To

The Surgeon-General with the
Government of Madras,
Madras.

Sir:

Ref: No.34116-23 B/48 D/11-7-1949 -
Chief Engineer's No.6755-P.W.W.48-4
D/20-6-49.

Sub: Grant - Building private Medical - St. Joseph's Leprosy Hospital, Kankanady - Plans and estimates revision of.

Revised plans and estimates of the above as required were submitted on 11-8-49. I request that permission to start the work may kindly be granted at least of the Hospital Block and of the Operation Theatre. The estimate may be scrutinised in due course of time if not already done.

We are at the close of the monsoons and so atleast the basement must be completed by the end of October ∅ in order to enable us to proceed with the work later.

Reg. Pinto

DIRECTOR
St. Joseph's Leprosy
Hospital & Asylum,
Kankanady, Mangalore.

Medical Department

From
The Director, St. Joseph's Leprosy Hospital and Asylum,
Kankanady, Mangalore.

To
The Surgeon-General with the Government of Madras,
Madras-6.

Ref: No.34116-23-B/48 D/11-7-49 and Chief Engineer's No. 6755-P.W.W./48-4 D/20-6-49

Sub: Grant - Building - Private - Medical Institutions - St. Joseph's Leprosy Hospital & Asylum at Kankanady - Plans and estimates - revision of

Sir:

With reference to the above I resubmit herewith the plans and estimates duly revised as per instructions of the --- Chief Engineer.

Para 2. New block for women patients:-
Since the construction site was changed to S. No.14 where the soil and sub-soil met with is of laterite strata with little gravel, the provision for vertical joint was not made in the estimate. Since it is again pointed out in C. E8s No. quoted above, necessary provision for extra truss has now been made in this estimate.

Para 2(1) Structural calculations for pressure of soil, sizes of timbers, etc are furnished now. Regarding the trusses, it is proposed to have the trusses, of 18'-0" span at 10'-0" apart and the sizes of members as detailed in the M.D.S.S will be adopted and hence no separate calculations are furnished.

2(2) Width of foundation concrete will be only 3'-0" and 1'-0" thick and the masonary footings and basement will be 2'-0" and 1'-6" respectively depending on the size of the stones 18"x9"x6" available. The masonary foundation height has been altered from 2'-0" to 2'-6" since the depth of concre is kept up to 1'-" which is found to be sufficient, as the soil and sub-soil being laterite strata mixed with little gravel. Necessary corrections since made in the plan and estimate.

2(3) Instructions noted and the work will be done as per --- instructions.

2(4) Since included in the estimate for the main block.

2(5) Damp-proof course has since been provided in the estimate for all main walls excepting the verandah retaining walls as per M.D.S.S. No.38.

Para 3
3(1) Operation Theatre:-
All wood work will be of best Kirolbhogi wood. The shutters will be of jack wood. Teak wood will be used for shutters if avaialable. All the other remarks noted and will be attended to during execution.

Kitchen:-
Structural calculations for all items have now been furnished The provision of a second strore room and staircase room have been omitted, considering the economy in cost of the work and a ladder has been provided in the kitchen room itself for admission into the loft.
Damp-proof course with cement mortar ¼" thick as being done usually, also has been included in the estimate.

Septic tank:-
The location of the septic tank and dispersion trench have now been shown on the plan. All the remarks since noted.

The recent designs mentioned are not readily available in any of the offices here. Necessary corrections in the estimate or fresh estimate will be prepared soon after receipt of the revised recent designs from the Sahitary Engineer to the Government of Madras.

Para 6. Compound wall:-
Remarks noted and will be attended to during execution.

7. The plans and estimate has since been revised in the light of the remarks of the Chief Engineer, and resubmitted herewith for early sanction.

In this connection I have to mention that this is the best time for excavating foundation, soil being little bit soft due to rains as well as to start the masonary work, as much water will not be necessary. Further there will be dearth of supply of water during summer after February and the available water we get from all the wells together at times will be just sufficient for the use in the hospitals.

I therefore request that permission may please be granted to start the work as per this estimate duly revised in the light of the remarks of the Chief Engineer vide his No.6755-P.W.W./48-4 D/20-6-49, so as to facilitate me, to complete the work early before the time when water supply is restricted.

Mangalore
Dated 11-8-1949

Sd. Reg. Pinto

Director
St. Jospeh's Leprosy Hospital
Kankanady.

Enc. Estimate duly revised in duplicate 1
Plan of new block 1
Plan of operation theatre 1
Plan of kitchen 1
Plan of compound wall 1
Plan of septic tank 1
Old estimate with site plan 1

Sd. M. Venkatramayya
Retd A.E., P.W.D.

TRUE COPY

Kankanady
26th Sep 1949

Reg. Pinto
Dr.

Medical Department

From

Dr.A.S. Mannadi Nayar, M.B.B.S., Ph.D. (Edin.),
Surgeon-General with the Government of Madras.

To

The Secretary to Government, Education and Public Health Department, Madras.

Ref.No.34116-29-B/48 dated 29-9-49.

Sir,

Sub:-Grants - Buildings - St.Joseph's Leprosy Hospital, Kankanady - Revised plans and estimates.

Ref:-Correspondence resting with Government Endorsement No. 79217-G1/48-14 P.H. dated 24-9-49.

I enclose herewith a copy of letter No.*D/3219 dated 28-9-49 received from the Director, St.Joseph's Leprosy Hospital and Asylum, Kankanady for the information of Government and request that the plans and estimates already submitted to Government may kindly be returned duly approved at a very early date.

Yours faithfully,

for Surgeon-General with the Govt. of Madras.

D/29/9-

Copy of letter*

Sub: Grant - Building private Medical - St.Joseph's Leprosy Hospital, Kankanady - Plans and estimates Revision of -.

Revised plans and estimates of the above as required

Required were submitted on 11-8-45. I request that permission to start the work may kindly be granted at least of the Hospital Block and of the Operation Theatre. The estimate may be scrutinised in due course of time if not already done.

We are at the close of the monsoons and so atleast the basement must be completed by the end of October in order to enable us to proceed with the work later.

/True copy/

for Surgeon-General with the Govt. of Madras.

D/26/9-

EPH Gl

Memo 79217 Gl/48-15 PH dt 8-10-49

Subj:- Grant - St Joseph's Leprosy Hospl. & Asylum, Kankanady - Constn. of additional buildings - Revised plans & estimates - Approval of.

Ref:- From the Director, St Joseph's Leprosy Hospl. & Asylum, Kankanady letter dt. 26.9.49

The Director, St Joseph's Leprosy Hospital and Asylum, Kankanady is informed that orders in the matter will issue shortly.

for Secy

To

The Director, St Joseph's Leprosy Hospl & Asylum Kankanady, (S. Kanara Dt)

7.10.49

7.10.49

Ref. No.34116-30-B/49. Office of the Surgeon-General with the Govt. of Madras, Madras, 29-9-1949

From

The Surgeon-General with the Govt. of Madras, Madras.

To

The Director, St. Joseph's Leprosy Hospital & Asylum, Kankanady, P.O., S.India.

Sir,

Subject-Grants-Buildings-St. Joseph's Leprosy Hospital, Kankanady - revised plans & estima

78920 Ref:-your letter No.D/3219 dated 26the Sep.1949.

The Govetnment has been reminded in the matter and their orders will be communicated to you on receipt.

Sd. .....
for Surgeon-General with the Govt. of Madras.

St. Joseph's Leprosy Asylum Leprosy Hospital & Asylum,
Kankanady P. O.,
MANGALORE,

№ D/3388 10th October 1949.

From

Rev. Reginald Pinto,
Director,
St. Joseph's Leprosy Hospital & Asylum,
Kankanady, ~~S. India.~~ Mangalore

To

Joseph M. Lobo Prabhu Esq., I. C. S.,
Jt. Secretary to the Government of Madras
Public Health Department,
Fort St. George, Madras.

Sir:

Subject: Grants - buildings - Extension to St. Joseph's Leprosy Hospital & Asylum, Kankanady - revised plans and estimates.

Ref: No.34116-30-B/49 dated 29-9-1949 from the Surgeon-General with the Government of Madras.

I herein enclose a copy of the Surgeon-General's reply cited above to our reference No.D/3219 dated 26-9-1949, a copy of which was sent to you also. In this connection, I beg to state that the work of construction of the Leprosy Extension buildings ought to have been taken up during the last S. W. Monsoons but this not done, we will have to atleast depend upon the remnants of the casual N. E. Monsoons blowing on this side of the coast which usually commences in this month itself. We had therefore to avail ourselves of this opportunity immediately and take up construction work as the earth work of excavation for the foundation was finished during the monsoons. When you were in Mangalore, the other day, I approached you with a request kindly to inspect the locality and you were pleased to inspect the site and you would be in a better position to lay the matter before Government for immediate orders. I also take this opportunity of informing you that the Hon'ble the Premier for the Government of Madras, has been requested to lay the foundation stone of the Leprosy block and it is hoped that he will accept the invitation.

As we are now depending solely on the N.E.monsoons to a very limited extent, we have taken the work of construction of the female block and theatre which are free from objections immediately as otherwise the work of construction would have to be postponed indefinitely for another year.

In these circumstances, I pray for orders urgently.

I have since received Government memorandum No.79217 G1/48-15 P.H. dated 8-10-1949, but I am pushing forward this letter in view of the urgency explained above.

Yours faithfully,

Reg Pinto

DIRECTOR
St. Joseph's Leprosy Hospital & Asylum,
Kankanady, S.India.

Edn & H.

Subject: Buildings - Private Medical institutions - St. Joseph's Leprosy Hospl. and Asylum, Kankanady - Revised plans and estimates — Approved.

Read: G.O. no 1287 P.H dt 20.4.48

Read also:—

1. Letter from the S.E. no. 34116-1213/48 dt 26.10.48
2. Letter from the Chief Engineer no 6753-PWW/48-4 dt 20.6.49
3. Letter from the S.E. no 34116-2768/48 dt 17.8.48.
4. Letter from the Chief Engineer no 6753-PWW/48-7 dt 24.9.49

Order no 3590 P.H dt 12.10.49

The Govt. approve the revised plans and estimates for the construction of additional buildings (except the Chapel) in the Leprosy Hospl at Kankanady ~~as~~ subject to the following orders:—

(1) The suggestions made by the Chief Engineer in his letter dated 24.9.49 (copy enclosed) should be carried out.

(2) The Govt grant for the work will be restricted to ~~the maximum~~

Note Amount ~~Order~~ Sanctioned
Lgfks. 49750/- sanctioned in Govt. No. 1287/Pl
D 20.4.48

DRK
12.10.48

12.x.48

To

The Lt. Civil Affairs Officer
" Lt. P.W.D.
Building.
" Director,
~~Police Station, Kohat~~
~~Police Lines~~
Dr. Forests, Kohat.
" Deputy Commissioner
~~Executive Engineer~~
" Civil Surgeon, Kohat
" Sub-Divisional Officer
" Executive Engineer
By Regd Post
with acknowledgement due
" Deputy Commissioner
Kohat
Fin Secy.
P.W.D
2 C/Cs. for D/A.

Copy with Govt. No. 1287/Pl
to Lt. Col. Civil Affairs Officer
Kohat
for information
to Lt. Col. Civil Affairs Officer
Kohat
for information
to Executive Engineer
Kohat
for information
to Executive Engineer
Kohat
for information
to Executive Engineer
Kohat
for information

Subj:- Grant-in-aid to St Joseph's Leprosy Asylum, Kankanady - Half grant for construction of addl. buildings.

Secy

Grant for medical buildings
Leprosy Asylum, St Josephs
Mangalore (Kankanady).

Instructions & Grant
Plans etc have come
up for the approval.
May I have them, please.
Thanks.

27/5/48

Ref:- Joint Sec's note above:- A half grant of Rs 49750/- has been sanctioned for the Kankanady Leprosy Asylum in GO No. 1287 SH 2/20.4.48. The SA was asked to get the original plans & estimates in respect of the additional buildings recast on the lines of the suggestions of the C.E. The revised plans & estimates have not yet been received. A draft reminder is submitted for approval.

(A)/pp5-8/cf

2
29/5/48
27.5.48

The plans & estimates have since been received & hence further submission of this file to J.S. has been interrupted. The revised plans &

estimates maybe referred to the CE for remarks if any before according approval. Subject to orders a draft-order is submitted for approval:

[Issued as Order No. 79217 G2/48-1 (PH) D/5-11-48] pp3 cf
From the CE. No. 6755. PWW/48-2 D/28-12-48. pp11-12 cf

With reference to the Order on p3 cf. please see the remarks of the CE on pp 11-12 cf. He states that in the circumstances stated by para 4 p12 here, the plans & estimates furnished by the Director of the Leprosy Asylum are not in a Complete state to be approved. He therefore suggests that the Director maybe asked to furnish the particulars referred to by him. to enable proper scrutiny of the plans & estimates. In the circumstances stated by the CE the SG maybe asked to obtain furnish orders & this required particulars. Subject to orders a draft memo is submitted for approval.

8.1.49.

[Issued as Memo No. 79217 G2/48-5 PH D/8-1-49] pp13-14 cf
From the Director, Trivandrum letter d/22 Aug p15 cf
~~Issued~~ Issued as Memo No 79217 G2/48-6 PH D/26-Aug p17 cf

---

With reference to the minutes of HH(PH) on p 17 c.f. it is submitted that the plans & estimates furnished by the Director of the Leprosy Asylum were not in a complete

State to be approved by Govt. The plans & estimates have been returned to the SG and he has been asked to get them recast by the Director on the lines suggested by the Chief Engineer & to submit them to Govt at an early date for according the necessary approval.

2. In this letter at page 15/c, the Director of the Asylum requested early orders on the matter. With reference to this, the SG has been reminded to get get the necessary revised plans from the Director at an early date. His reply is awaited. A copy of the memo to the SG has been sent to the Director also. In the circumstances it does not appear necessary to send a reference to the Director at present. On receipt of the necessary revised plans & estimate from the SG, they may be approved by Govt.

This was received when HH(P&H) was away to S. Kanara

3 HH(P&H) may see

2/4/49 JRK 2/4/49

We are having too many enquiries in respect of the details of construction for which only a lump grant is being given. However we must now wait for the S.G to get to obtain revised estimate, which will have to be shown to C.E again

Matter may be expedited. MMS 2/3

2/3/49 HH(P&H)

from the Director letters dated 23.8.48 & 1.3.48 /pp 21 & 25 c/f.
From the SG no. 34116-16B/48 D/3.3.48 — /p23c/f

Please see the orders in circular
hon ornp 3 above. The SG has since reported /p20 c/f
that the plans & estimates have been
forwarded to the Director of the St. Joseph's
Hospital for revision and that they would
be intimated to Govt on return. The Director
has also written stating that the revision /pp 21 & 25 c/f.
of the plans & estimates has already been
undertaken & that the revised ones will be
speedily sent. In the circumstances, there
Seems to be no need to hurry up the SG.
revised
the Plans & estimates may be awaited.

3
8.3.48.
JKR
8/3/48.

From the S. G., Rc. no. 34116-21-B/48, dated 7.5.1948. /pages 33 21 c/f

---

The revised plans and estimates now /p 20 c/f
received by the S. G. may be referred to the C.E. again
for further scrutiny and remarks, if any. The
draft below is for approval.

8/5/48 — 10/5/48

Issued as Memo no. 79217 GA/48-8TH D/2549 /p35c/f.
From the CE, PWD, letter no. 6755 DWK/48-4
Dated 20.8.48 /pp 37-35c/f

The Chief Engineer, to whom the revised plans & estimates submitted by the SG. were sent for scrutiny, has now returned them together with his remarks - vide pages 37-38 c/f. In the circumstances stated by him, he states that the plans & estimates may be returned to the Director of the Hospital, for getting them recast on the lines indicated by him. The draft memo below is therefor for approval.

2
25 Aug
JRK
25.8.49

28/8/49

D.S
K
29/8/49

pp 39-40 c/f - Issued as Memo. 79217 G1/48:9 DH D/29 8 49
pp 41-42 c/f - From the SG no. 3446:27 B/48 D/ 19.8.49.

The plans & estimates which were sent to the Director of the Hospital for recasting on the lines indicated by the CE in his letter on pp 37-38 c/f, have since been duly revised by the Director. The SG has now revised plans & estimates kept in Section of the Hospital are at (iv). They may be sent to the CE for scrutiny, in the first instance. Subject to orders a draft memo is submitted for approval

2
23 Aug
JRK

Recd 29/8/49

pp 44-45 c/f - 23/8/49 [Issued as Memo no. 79217 G1/48.12 DH D/ 24.8.49]

pp 46-47 c/f - From the CE PWD, Letter no. 6755 BWN/48-1 D/ 24 9 49

From the Director of the Hospital, letter D/26 9 49

With reference to the letter at page 51 C/, from the Director St. Joseph's Leprosy Hospital & Asylum at Kankanady it is submitted that the revised plans & estimates each of recast by the Director Architect on the lines indicated by the CE in his letter on pp 37-38 C/, were forwarded to the CE for scrutiny. The CE has now returned them together with certain suggestions for further alterations to be carried out in the revised plans & estimates. As it may take further time, if the plans & estimates are once again sent to the Director for recasting & return to Govt, the CE may be consulted whether it would be in the Govt can even now accord approval of the plans & estimates, subject however to the condition that the Director carries out the alterations indicated by the CE, in due course. Subject to orders a draft memo is submitted for approval. Secretary may see perhaps with reference to his remarks on p 51 C/

This is what the C.E has clearly and in detail in his covering remarks at 49 C/.

Not necessary
H

It does not seem necessary to waste any more time in making a further reference to the CE. The plans and estimates may be approved subject to the condition that the Director carries out the alterations suggested by the CE. in due course. Secy may see after issue of orders.

2
H 10/12
JPR
4.10.12

G
E
4.10.12

Not necessary
H.

A.D.P.

4/10. H 5/10.

above: According to the original estimate for the construction of the buildings, total cost was estimated at Rs99,500. Govt therefor sanctioned in GO no: 1287 dated 20.4.48, a half grant of Rs 49,7 to the authorities of the St Joseph's Leprosy Asylum & Hospital, towards the constn. of the buildings. According to the revised plan & estimates, as scrutinised by the ~~SE~~, CE the total cost of the work amounts now to Rs 1,10,000/- The half grant payable by Govt on this basis would therefore be Rs 55,000/- As a half grant of Rs 49,750/- has already been sanctioned by Govt, the extra cost to Govt would now be Rs 5,250/- only. This amount may be sanctioned as an additional grant, during the current year, itself. For orders.

49,750
Rs 5,250 ✓

2. Pending the issue of orders, approving the revised plans & estimates, and sanctioning the payment of an additional grant of Rs 5,250/- the Director of the Hospl may w.r.t his letter dt 4.9.49 be informed that orders in the matter will issue shortly. Subject to orders, a draft memo is submitted for approval. After issue, the file may be sent to Finance for remarks, if any on D.D.M.(P.H).

4/

2
7.10.49
JRK
7.10.49

ASSISTANT SECRETARY TO GOVERNMENT
10 OCT 1949
6586/I&A
FINANCE DEPARTMENT

7.10.49 ASF

I do not see any need to increase the grant - ~~sanction~~ in the estimate may be sanctioned subject to the original Rs 49,750 already sanctioned. Either way the amount will go on increasing with revised estimates.

7/10 Thiru (a.c)

④ Of the excess savings in actual execution or find expenditure extra are exceptions.
Memo 79217 Gl. Instr -16
8.10.49

2. Please see the orders on page 6 above. According to the original estimates for the construction of the buildings, the total cost was estimated at Rs99,500. The Govt. thereon sanctioned in Go no. 1287 Hy dated 20.4.48, a half grant of Rs 49,750/ to the authorities of the St. Joseph's Leprosy Asylum & Hospital, towards the consn. of the buildings. According to the revised plan & estimates as scrutinised by the ~~EE~~, CE the total cost of the work amounts now to Rs 1,10,000/- The half grant payable by Govt on this basis works therefore be Rs. 55,000/- As a half grant of Rs 49,750/- has already been sanctioned by Govt, the extra cost to Govt works now be Rs 5,250/- only. This amount may be sanctioned as an additional grant, during the current year, itself. For orders.

55,000
49,750
5,250

2. Pending the issue of orders, approving the revised plans & estimates, and sanctioning the payment of an ~~half~~ additional grant of Rs 5,250/- the Director of the Hospl may be informed w.r.t his letter dt 4.5.49 that orders in the matter will issue shortly. Subject to orders, a draft memo is submitted for approval. After issue, the file may be sent to Finance for remarks, before ~~on~~ 7.10.49 (P.A)

2
7.10.49

ASSISTANT SECRETARY TO GOVERNMENT
10 OCT 1949
6586 I&A
FINANCE DEPARTMENT

I do not see any need to increase the grant - ~~distribution~~ in the estimate may be sanctioned subject to the ceiling - Rs 49,750 already sanctioned. Either way the amount will go on increasing with further revised estimates.

7.10.49

Thro 79217 G.I Instr -16
8.10.49

Thro (a-2)

① Are there any chance savings in actual execution or final lumpsum extra are the estimates.

Finance (Exp A)

In G.O 1287 P.H dated 20.4.48 the Govt. sanctioned a half grant of Rs 49,750 to the authorities of the St. Joseph's Leprosy Asylum and Hospital, towards the construction of buildings. This file deals with proposals for the approval of the revised plans and estimates relating to the construction of the buildings. The note of E.P.H on p7 above may be perused.

Finance may entirely agree with the views of Addl Secretary, E.P.H, at the bottom of p7 above. That there is no need to increase the half-grant based on the revised estimate and that the revised estimate may be sanctioned, subject to the grant of Rs 49,750 already sanctioned, on the basis of the original estimates, remaining unaltered.

Rs
11.10.49

VKK
11.10.49

(M 57-58 F ; 1)

BJ
12.X.49

Fin Exp A: 65861-1

12.X.49

01

In G.O 1287 P.H dated 20.4.48 The Govt sanctioned a half grant of Rs 49,750 to the authorities of the St. Joseph's Leprosy Asylum and Hospital, towards the construction of buildings. This file deals with proposals for the approval of the revised plans and estimates relating to the construction of the building. The note of E.P.H on p 7 above may be perused. Finance may entirely agree with the views of Addl Secretary, E.P.H, at the bottom of p 7 above. That there is no need to increase the half-grant based on the revised estimate and that the revised estimate may be sanctioned subject to the grant of Rs 49,750 already sanctioned, on the basis of the original estimate, remaining unaltered.

M 57-58 F

RS
11.10.49

VSK
11.10.49

RS
12.X.49
EXP H

1st Nil ExpA. 65861-I
12.X.49